5/11/00

WORK LOG

Date & Time Started:	8/1/00 0800
Work Comments:	
Heat Tape test .89 amps	
System functional	

Date & Time Completed	8/21/00	1600
Work Completed By		Electrician - Russell
	Craftsman	- Smith
Work Reviewed By	[signature]	8/21/00
	FPM	
Work Accepted By	[signature]	
Pete Rojas 9-7-00	Building Engineer	